



The minimum thickness for the integral/monolithic precast base is 6" thick for structures 14' deep or less, and increases 1" in thickness for every 4' of depth greater than 14'.

NOTE:

1. Kor-n-seal manhole or equal considered acceptable alternate.
2. All dog houses shall be grouted on inside.
3. When the manhole structure is constructed outside the traveled roadway a witness post and sign (MH) shall be installed next to the manhole.
4. Minimum of 2-2" adjusting rings, maximum of 3 adjusting rings or a total of 8" of stack height for new construction.
5. No steps shall be installed in manholes, any steps removed shall be pulled and the holes grouted.



**CITY OF
CHANHASSEN**

STANDARD
SANITARY SEWER
MANHOLE

REVISED: 1-21

FILE NAME: G:\ENG\SPECS\2101

ENGINEERING DEPARTMENT

PLATE NO.:

2101